

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Doon International School Jammu
Chowadhi, near Sainik Colony
Jammu

No: JDF&ES/FPI/2246

Dated: 03.05.2021


Sub: Fire Safety Certificate.

Ref: Your letter No.DISJ/647/20-21 dated: 08.03.2021.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Hose Reel Hoses and First Aid Fire Extinguisher in their school premises. The school is about 09 Km away from Fire & Emergency Station Gangyal Jammu and is approachable for fire appliances in case of any emergency. Since the school is already functioning as such the management can proceed ahead for operation subject to adopt the following fire safety measures in letter and spirit forthwith for effective and betterment of the school:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exists/staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. No Hazardous material should be kept inside the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. Fire fighting system installed in the building should be checked periodically. Staff should be fully trained in handling/operating of fire fighting system installed in the building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments is functioning.
6. The corridor of the building shall not be used for any kind of storage.
7. The management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
9. At present school is having three triple storied blocks. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
10. The validity of this clearance shall remain in force for one year and final fire safety certificate shall be issued after checking/inspection of fire fighting system recommended by this department.


CHAIRMAN
DOON INTERNATIONAL SCHOOL
JAMMU.
C.B.S.E. CODE - 730087

Yours Faithfully


Joint Director
Fire & Emergency Services
Jammu Range, Jammu


Doon International School